

## TENDER ADDENDUM

Tender Addendum Ref. 1Date: 08-03-2017Package: Petra Museum Exhibition

يعتبر هذا الملحق جزءاً لا يتجزأ من وثائق العطاء

No.	Query	Response
1	Kindly provide the types of wood to be used for each item for finishing works.	Gallery 4: Oakwood, flat-grain type Gallery 8: Oakwood, edge-grain type The actual material will be determined by the engineer checking samples.
2	Kindly provide more details for the picture rail to be used for the project.	The maximum capacity shall be 25kg per 1 meter.
3	Should the monitors be provided by the contractor, if so, kindly provide specifications.	The monitors will be provided by others.
4	Kindly provide further details of the water tunnel to be used.	Floor: the recessed area shall be painted in blue phosphorescent paint and illuminated with black light fixture. Wall and Ceiling: the surfaces shall be painted in blue. Line type LED light fixture shall be used as indirect lighting. The installation location of the light fixtures shall be checked and decided by the engineer on site.

- The exchange rate of USD/JOD is 0.708 during the project implementation.
- Monitor Box (drawing D10) and Digital Signage Stand (drawing D11) should be compatible with VESA standard for the mounting method.